


730 Howe Avenue, Suite 450 Sacramento, CA 95825 Phone: 916.921.2112 Fax: 916.921.2212

March 9, 2024

Henry + Associates Project No. 23-34-026

ADDENDUM NO. 02 CULINARY LAB VENTURE ACADEMY SAN JOAQUIN COUNTY OFFICE OF EDUCATION Stockton, California





.....

- 1. <u>ALL WORKMANSHIP, MATERIALS, APPLIANCES AND EQUIPMENT</u> which may be included in the following items shall be the same relative quality as described for similar work set forth in the original or main specifications of which these Addendum items shall be considered a part.
- 2. <u>ADDENDUM DRAWINGS</u> (included in the back of this Addendum). The following Addendum drawings modify or supplement the issued bid documents:

AD2.01 ADDITION TO SHEET A1.1.2 SITE PLAN

C:\Users\Owner\Dropbox\Henry + Associates Architects\Projects Active\23-34-026 Culinary Lab Venture Academy\2const\C01 BID Pre-Bid Administration\Addenda\Addenda 02\Addendum 02.DOC March 9, 2024 Addendum No. 02 CULINARY LAB VENTURE ACADEMY Page 2

- 3. PROJECT MANUAL:
 - A. None
- 4. <u>DRAWINGS</u>:
 - A. Sheet A1.1.2: Attach Addendum Drawing AD2.01 to sheet A1.1.2.
 - B. Sheet E001:
 - 1. Revise FIRE ALARM GENERAL NOTES:
 - a. Note 1: Revise "DSA" to "Stockton Fire Department".
 - b. Note 2: Remove "DAS".
 - c. Note 5: Revise "DSA" to "Inspector"
 - C. Sheet E410:
 - Add the following note to FIRE ALARM RISER DIAGRAM: "THE EXISTING FIRE ALARM PANEL IS SIEMENS MXL-IQ. NEW AND EXISTING FIRE ALARM CONTROL PANELS SHALL BE INTERCONNECTED TO WORK SIMULTANEOUSLY; A FIRE ALARM CONDITION ON ONE PANEL SHALL TRIGGER A FIRE ALARM CONDITION ON THE OTHER PANEL. THE EXISTING FIRE ALARM PANEL SHALL BE USED AS A MAIN PANEL (IT IS CONNECTED TO THE MONITORING COMPANY – SONITROL). ENSURE THAT SILENCING BOTH PANELS CAN BE DONE FROM ONE LOCATION (FROM ONE PANEL).
 - D. Sheets C1 and C2: Add the following note: TWO OPTIONS ARE PROVIDED FOR CONNECTION OF THE SEWER LINE. ONE LOCATION CONNECTS OUT IN THE STREET. IF THE CONTRACTOR ELECTS TO CONNECT IN THE STREET, CONTRACTOR SHALL OBTAIN AN ENCROACHMENT PERMIT FROM THE CITY OF STOCKTON.
- 4. OTHER:
 - A. Attached to this addendum is the sign-in sheet from the second Pre-Bid meeting.

* * * END OF ADDENDUM * * *

C:\Users\Owner\Dropbox\Henry + Associates Architects\Projects Active\23-34-026 Culinary Lab Venture Academy\2const\C01 BID Pre-Bid Administration\Addenda\Addenda 02\Addendum 02.DOC



ADDENDUM DRAWING AD2.01 - ADDITION TO SHEET A1.1.2.



730 Howe Avenue, Suite 450 Sacramento, CA 95825 Phone: 916.921.2112 Fax: 916.921.2212

May 1, 2024

Sign-In Sheet **Mandatory** Pre-Bid Meeting Culinary Lab Venture Academy San Joaquin County Office of Education

	Company Name/License No.	Representative	Phone	Email
1	AMStephens	Jake Sebaugh	925-876-2756	steve @anistephens.net
2	F&H Construction	Riley Jones	209-931-3738	s estimating@f-hconst.com
3	SJCOE	Tim Sutton	204.406.7229	Tisettone sscor. wet.
4	HENRY + ASSOCIATES ABOUT 1889	STEPHENHENG	9167993027	stephene henry - architectr. com
5	STUE	Erroveite	209-468-8071	Crancessor.net
6	Boakmon + Wordy	Armando Maveno	209-471-01A2	armando. Moveno e Lackmon Woody . Com
7				
8				· · · · · · · · · · · · · · · · · · ·
9	· · · · · · · · · · · · · · · · · · ·			
10				